

Message

From: Baron, Adam [/O=EXCHANGELABS/OU=EXCHANGE ADMINISTRATIVE GROUP (FYDIBOHF23SPDLT)/CN=RECIPIENTS/CN=563EF058707D4930868C6CF1E0828A43-BARON, ADAM]
Sent: 10/16/2019 9:07:30 PM
To: Chico Holliday [chico.holliday@wstribes.org]
Subject: Sidwalter sig defs

Chico –

I looked this one up. Here were most recent sig defs. Did this work already get done? Did you provide documentation back to EPA? If so please forward to me and I'll clean it up on our side.

Deficiency	Schedule to Address Deficiency		Accomplishments (date completed)
	Milestone/Corrective Action Description	Scheduled Date	
Sources - #4 Is there a sample tap provided on the well discharge pipe following treatment			
Sources - #6 Is well vent screened with the return bend facing downward and terminating 18-inches above ground level or above minimum flood level, whichever is higher			
Sources - #7 Are conduits and junction boxes sealed to prevent contaminants from entering the well casing			



Adam Baron

Drinking Water Enforcement Officer
Field, Data, & Drinking Water Enforcement Section
Enforcement and Compliance Assurance Division
U.S. Environmental Protection Agency, Region 10
1200 Sixth Avenue, Suite 155
Seattle, Washington 98101
Office (206) 553-6361
baron.adam@epa.gov